



Energy Audit Summary Report

Austrian Energy Agency

Audit 67 – AUT11

Service/Production
Industrial Laundry



AUSTRIAN ENERGY AGENCY

17.07.2012

AUDIT no. 67 – AUT11

Industrial Laundry

1. Data of the auditor

1.1. Contact data of the auditor

Konstantin Kulterer, Austrian Energy Agency. The audit was performed on 14. May of 2012.

2. Introduction

2.1. Objectives

Status-Quo analysis on efficiency level of this industrial laundry, plan strategy for energy efficiency improvements.

3. Status Quo: processes, distribution, energy supply

3.1. General info of company

Industrial laundry, (laundry of hotels, professional clothes, hospitals, old peoples home)

Working time: 5-6 days (16 h/day), 285 days a year

3.2. Flow sheet of the whole manufacturing side (processes, distribution, energy supply) in form of a block diagram




Figure 2.3.1.1: Useful process heat (UPH) by process

Table 2.1.1 Total primary energy consumption (PEC) and primary energy consumption for thermal use (PET)

| Energy type (fuels / electricity) | PEC | | PET | |
|------------------------------------|---------------|---------------|---------------|---------------|
| | [MWh] | [% of Total] | [MWh] | [% of Total] |
| Total fuels | 16.689 | 70,97 | 16.685 | 100,00 |
| Total electricity | 6.828 | 29,03 | 0 | 0,00 |
| Total (fuels + electricity) | 23.517 | 100,00 | 16.685 | 100,00 |

Table 2.1.3. Final energy consumption for thermal use (FET) by equipment (present state).

| Equipment | Fuel type | FET by equipment | |
|--------------------|-------------|------------------|--------------|
| | | [MWh] | [% of Total] |
| Dampfkessel | Natural gas | 13.248 | 87,35 |
| Trocknergruppe Gas | Natural gas | 766 | 5,05 |

| | | | |
|--------------|-------------|---------------|---------------|
| Finisher | Natural gas | 1.152 | 7,60 |
| Total | | 15.166 | 100,00 |

There are two distribution systems: The main part is a steam distribution system 10/9 bar. The other main heat consumers are directly supplied with gas.

Dryers, Tumble dryer produce heat of 200°C but only at the beginning of the drying process, later on this temperature goes down to 120°C. The calanders (Mangel) are heated with 200°C. The washing processes have a temperature of around 70°C.

The main energy using processes are as mentioned above: Several dryers, calanders, tunnel washer, washing machines and finisher, presses and sterilisators. For the heating of the building only minor energy consumption was reported and not modelled in EINSTEIN.




Figure 3: heat and cold demand over the temperature – present state.

3.4. General

No additional measurements were made.

4. Comparative study

4.1. Proposed alternatives

| | |
|----------------------------------|--|
| New Proposal WT Trockner | This proposal consists of one heat exchanger: For the preheating of the air inflow for one group of four steam dryers by the waste heat of the same dryers. It has a high saving effect at reasonable costs. |
| New Proposal WT Calander | Further energy savings are possible with the installation of another heat exchanger between the waste heat of the calander and the inflow of the tunnel washer. This alternative has also excellent pay back time. |
| New Proposal WT Trockner and KWK | This proposal consists of the heat recovery system in alternative 2 and a CHP. |
| New Proposal KWK | This proposal consist of an new CHP only. |

Solar-thermal was modelled in EINSTEIN but this alternative did not provide economic savings. Heat Pumps were excluded of the analysis.

Table 4.1. Primary energy consumption: present state and alternative proposals.

| Alternative | Primary energy consumption | Savings | |
|---------------------------------------|----------------------------|---------|-------|
| | [MWh] | [MWh] | [%] |
| Present State (checked) | 23.517 | --- | --- |
| New Proposal 1 HX T 11- T 14 | 22.255 | 1.262 | 5,36 |
| New Proposal 2 WT Mangel 1 Waschstr 2 | 21.128 | 2.389 | 10,16 |
| New Proposal WT Netzwerk und KWK | 17.785 | 5.732 | 24,37 |
| New Proposal 4 KWK | 20.121 | 3.396 | 14,44 |

5. Selected alternative(s) and conclusions

5.1. Selected alternative

The selected alternative is the heat exchanger network (two group of heat exchangers) in combination with a gas-turbine (CHP).

5.1.1. Heat Supply System and Heat Recovery Network

Table 5.1.1.1 Heat and cooling supply equipment and contribution to total supply. Final proposed solution.

| Equipment | Type | Heat / cooling supplied to pipe/duct | Nominal capacity | Contribution to total heat / cooling supply |
|-----------|------|--------------------------------------|------------------|---|
|-----------|------|--------------------------------------|------------------|---|

| | | | [kW] | [MWh] | [%] |
|--------------------|-------------------------|---|--------------|---------------|------------|
| New CHP 1 | CHP gas turbine | o==Dampfleitung 10 bar==o o==Trocknerleitung==o o==Finisherleitung==o | 938 | 4.540 | 37,84 |
| Dampfkessel | steam boiler | o==Dampfleitung 10 bar==o | 3.500 | 6.328 | 52,73 |
| Trocknergruppe Gas | burner (direct heating) | o==Trocknerleitung==o | 750 | 451 | 3,76 |
| Finisher | burner (direct heating) | o==Finisherleitung==o | 240 | 681 | 5,68 |
| Total | | | 5.428 | 12.000 | 200 |

Table 5.1.1.2 Heat exchanger network and amount of recovered energy

| Heat Exchanger | Power [kW] | Heat Source | Heat Sink | Heat transferred [MWh] | [%] |
|-------------------|------------|------------------------|------------------------|------------------------|------------|
| WT T 11 - T 14 | 269 | Dampftrockner T 11-T14 | Dampftrockner T 11-T14 | 997 | 52,45 |
| WT Mangel WStr. 2 | 190 | Mangel 1 | Waschstrasse 2 | 904 | 47,55 |
| | 459 | | | 1901,85 | 100 |




Figure 3.1.2.1. Pinch Analysis - Composite Curves




Figure 3.1.2.2. Pinch Analysis – Remaining yearly energy demand and energy availability

| | | Present state | Alternative | Saving |
|--|-----------------|----------------------|--------------------|----------------|
| <i>Primary energy consumption</i> | <i>[MWh]</i> | 23.517 | 17.785 | 5732 24,4% |
| - total | <i>[MWh]</i> | | | |
| - fuels (1) | <i>[MWh]</i> | 16.689 | 17.638 | -949 -6% |
| - electricity | <i>[MWh]</i> | 6.828 | 147 | 6.68 98%1 |
| <i>Primary energy saving due to renewable energy</i> | <i>[MWh]</i> | | 0 | -0 |
| <i>CO₂ emissions</i> | <i>[tons/a]</i> | 4.930,8 | 4033 | 898 18% |
| <i>Annual energy costs</i> | <i>[EUR]</i> | 735.827 | 605.928 | 129.899 18% |
| <i>Investment costs</i> | <i>[EUR]</i> | | 593.000 690.000 | |
| <i>Payback period</i> | <i>[years]</i> | | 3.2 | |

5.1.2. Energy and environmental analysis

The primary energy consumption could be reduced by 10 % by installation of two groups of heat exchangers, another 14% by installation of a CHP (gas-turbine). The CO2 Emissions would be reduced by 18%. The electricity consumption could be provided by the CHP therefore as a total the gas consumption would rise by 6%.

Table 6.1.1 Total primary energy consumption (PEC) and primary energy consumption for thermal use (PET)

| Energy type (fuels / electricity) | PEC | | PET | |
|------------------------------------|---------------|---------------|---------------|---------------|
| | [MWh] | [% of Total] | [MWh] | [% of Total] |
| Total fuels | 17.638 | 99,17 | 17.638 | 160,97 |
| Total electricity | 147 | 0,83 | -6.681 | -60,97 |
| Total (fuels + electricity) | 17.785 | 100,00 | 10.957 | 100,00 |

Table 4.4 Environmental impact: present state and alternative proposals.

| Alternative | Production of CO2 | Highly Radioactive Nuclear Waste | Water consumption |
|--|-------------------|----------------------------------|-------------------|
| | [t] | [kg] | [m3] |
| Present State (checked) | 4930,95 | 11,38 | 0,00 |
| New Proposal 1 HX T 11- T 14 | 4644,21 | 11,38 | 0,00 |
| New Proposal 2 WT Mangel 1 Waschstr 2 | 4387,93 | 11,38 | 0,00 |
| New Proposal WT Netzwerk und KWK | 4033,15 | 0,24 | 0,00 |
| New Proposal 4 KWK | 4566,08 | 0,19 | 0,00 |

5.1.3. Economic analysis

The total energy costs could be reduced by approx. 45.000 EUR (for the Heat Exchanger Alternative) and 130.000 EUR for the (CHP and Heat Exchanger Network), which means a reduction by almost 18%. The corresponding investment would be 110.000 EUR for the heat exchanger network and additional 550.000 EUR for the CHP. The pay-pack for the heat exchanger network would be below 2 years, in combination with the CHP the pay-back would be at 3.4 years.

Table 4.5 Investment cost: alternative proposals.

| Alternative | Total investment | Own investment | Subsidies |
|-------------|------------------|----------------|-----------|
| | [€] | [€] | [€] |
| | | | |

| Present State (checked) | --- | --- | --- |
|--|---------|---------|--------|
| New Proposal 1 HX T 11- T 14 | 80.000 | 56.000 | 24.000 |
| New Proposal 2 WT Mangel 1 Waschstr 2 | 140.000 | 98.000 | 42.000 |
| New Proposal WT Netzwerk und KWK | 690.000 | 593.000 | 97.000 |
| New Proposal 4 KWK | 550.000 | 495.000 | 55.000 |

Table 4.6 Total annual cost (fuels and electricity, O&M and annuity of investment): present state and alternative proposals.

| Alternative | Annuity | Energy Cost | O&M |
|--|---------|-------------|--------|
| | [€] | [€] | [€] |
| Present State (checked) | --- | 735.827 | 0 |
| New Proposal 1 HX T 11- T 14 | 5.887 | 699.115 | 8.000 |
| New Proposal 2 WT Mangel 1 Waschstr 2 | 10.301 | 666.312 | 14.000 |
| New Proposal WT Netzwerk und KWK | 50.771 | 518.495 | 36.662 |
| New Proposal 4 KWK | 40.470 | 586.200 | 22.802 |

Table 4.7 Total additional cost (w/o subsidies) per saved primary energy (PE): comparison of alternative proposals.

| Alternative | Total energy cost (incl. O&M and invest.) | Additional cost | Additional cost per saved PE |
|--|---|-----------------|---------------------------------|
| | [€] | [€] | [€/MWh] |
| Present State (checked) | 735.827 | --- | --- |
| New Proposal 1 HX T 11- T 14 | 713.001 | -22.825 | -18 |
| New Proposal 2 WT Mangel 1 Waschstr 2 | 690.613 | -45.214 | -19 |
| New Proposal WT Netzwerk und KWK | 605.928 | -129.899 | -23 |
| New Proposal 4 KWK | 649.472 | -86.355 | -25 |

Table 4.8 Internal rate of return (IRR) and net present value (NPV) of investment: alternative proposals.

| Alternative | Modified Internal Rate of Return | Pay-Back Period | Benefit Cost Ratio | Own Investment | Net Present Value (20 years) |
|---------------------------------------|----------------------------------|-----------------|--------------------|----------------|------------------------------|
| | [%] | [years] | [-] | [€] | [€] |
| New Proposal 1 HX T 11- T 14 | 14,9 | 2,0 | --- | 56.000 € | 478.252 € |
| New Proposal 2 WT Mangel 1 Waschstr 2 | 15,4 | 1,8 | --- | 98.000 € | 931.109 € |
| New Proposal WT Netzwerk und KWK | 11,8 | 3,4 | --- | 593.000 € | 2.725.473 € |
| New Proposal 4 KWK | 10,8 | 4,1 | --- | 495.000 € | 1.822.162 € |

5.1.4. Conclusions and outlook

Significant energy savings of 10% are possible by the installation of heat exchangers for the main waste heat flows (calander, dryers). In addition a CHP plant (gas turbine) can lead to significant savings of electricity almost of 100%.

As a first step the company should invest in one heat exchanger for one dryer and monitor the energy consumption. The next step would be to install all four dryers with heat exchangers.

The heat exchanger for the calander in combination with the pre-heating for the washing-tunnel needs a little more planning.

The CHP should be the planned in detail.